

UNITS PCB RECORDS
ANACONDA REDUCTION PLANT
COLUMBIA FALLS, MONTANA

UPDATED 5/30/80

*** TRANSFORMERS ***

ITEM DESCRIPTION	SERIAL #	LOCATION	CLASS IN PFM	WT. OF PCB LIQUID KG
W XFER B S0. 2000 KVA	YBR-91821	ROD CASTING	> 449	1260
W XFER B NO. 2000 KVA	YBR-91822	ROD CASTING	> 449	1260
GE RECL XFER 20,165.50 KVA	DS74670	REFL. STA. 3	> 45	1.5

*** CAPACITORS ***

ITEM DESCRIPTION	SIZE	LOCATION	CLASS IN PFM	WT. OF PCB LIQUID KG	PER UNIT
BNK CAPACITOR 50 KVAR WEST.					
124 UNITS	17"X13"X4"	SWYD., BANK 1	> 449	11.6	
32 UNITS	19"X13"X4"	" "	" "	12.8	
52 UNITS	21"X13"X5"	" "	" "	17.9	
					143.8
					41.3
					93.0
					278.1
					PIER

Sample results?
capacitors?

BNK CAPACITOR

ARCF00001191

FILE: PCB RECSAVE1 K4 Vn/CMS MEL 3 6/4/84

PAGE 002

50 KVAR WEST.		SWYD., BANK	449	UNIT	14.6
23 UNITS	17"X13"X4"	"	"		12.9
29 UNITS	19"X13"X4"	"	"		17.9
49 UNITS	21"X13"X5"	"	"		15.6
					<u>26.7</u>
					<u>374</u>
					<u>877</u>
					<u>1516</u>
<hr/>					
*** CAPACITORS ***					
ITEM DESCRIPTION	SERIAL #	LOCATION	CLASS IN PPM	WT OF FLUID KG	PER UNIT
CAPACITOR STYLE 1447256	TEST NO. 55A977X 55A980X 60J125 61B27 61B27 61B27	WELLHOUSE 4 WELLHOUSE 5 WELLHOUSE 6&7 WELLHOUSE 6&7 WELLHOUSE 6&7	> 449 " " " " "	6.0 6.0 6.0 6.0 6.0	42
CAPACITOR ELECT.	CAT NO 16F36662	CASTING AJAX FURNACE	> 449	23.0	437
CAPACITOR GENERAL ELECT.	CAT NO 16F3662	SPARE AJAX FURNACE	> 449	23.0	46
19 UNITS SIZE 1 3/4" X 5-1/2"					
2 UNITS					

10

4824

二

Total

43

四

How do these storage records
differ from those of File II?

STORAGE AREA
ANACONDA REDUCTION PLANT
COLUMBIA FALLS, MONTANA

NOTE: LISTED ITEMS STORED IN PCB STORAGE FACILITY
BARRELS WHICH ARE LOCATED IN RECYCLER STOREAGE S-2

UNIT DESCRIPTION & SERIAL NO.	CONTENTS OR LIG- NE WEIGHT KG	DATE OUT OF SERVICE	DATE IN STORAGE	DATE OUT OF STORAGE
77 W.CAPACITOR STYLE NO. 114725 TYPE FP TEST NO. 59H143	INTERNEEN 1.4 GA.			
(3) GE CAP CAT. 16F366G2 NO. X338337 NO. X29694 NO. 233836	PyRANOL	23,0 "		

* See P. 001 of File II

✓ See P. 002, File II
Cat #'s don't match

FILE: PCB

PAGE 004

REF ID: K4 VHS/CMS REC 3 6/1/84

(3) GE CAP
CAT. 46F366G3 PYRANOL

23,0

D I S P O S A L R E C O R D S
ANACONDA REDUCTION PLANT

ARCF00001194

FILE: PCB RECSAVE1 K4 VM/CMS REL 3 6/1/84

COLUMBIA FALLS, MONTANA

PAGE 005

UNIT DESCRIPTION & SERIAL NO.	CONTENTS DESCRIPTION	CONT OR LIQ WEIGHT (KG)	DATE PLACED IN TRANSIT TO DISPOSAL	OWNER'S NAME OF STORAGE OR DISPOSAL FACILITY
NONE				*

*

*

*

*

*

*

*

ARCF00001195